



TYPICAL SECTION

NOTES:

1. ALL NEW SIDEWALK CONCRETE TO BE AIR-ENTRAINED, LIMESTONE AGGREGATE AND FOUR (4) INCH MINIMUM THICKNESS. SIX (6) INCHES MINIMUM THICKNESS WITHIN DRIVEWAY LIMITS.
2. CONTRACTOR TO INSTALL CONCRETE SIDEWALK WHEN NECESSARY CONNECTING STREET SIDEWALK TO THE PROPERTY OWNERS HOUSE WALK. (WIDTH AND LENGTH WILL VARY)
3. PROVIDE 1/2 INCH EXPANSION JOINT MATERIAL AT JOINTS NOT EXCEEDING SIXTY FOOT INTERVALS.
4. CUT TRANSVERSE JOINTS IN WALK, EITHER SAWED, TROWEL CUT OR FORMED TO A DEPTH NOT LESS THAN 1/5 OF WALK THICKNESS. JOINTS TO BE 1/8 INCH MIN. WDE AND SPACED NO MORE THAN FIVE (5) FEET MAXIMUM ON CENTERS THROUGH OUT LENGTH.
5. LIGHT BROOM FINISH ON SURFACE.

CITY OF NEW PHILADELPHIA	STANDARD CONSTRUCTION DRAWING NO.
CONCRETE SIDEWALK DETAILS	SD-23
	REV. 10-99