



NOTES:

1. DUCTILE IRON WATER PIPE SHALL HAVE A MINIMUM OF 12" OF SAND GRANULAR BEDDING ABOVE AND BELOW THE INSTALLED WATER PIPE.
2. USE STONE FOUNDATION WHEN THE NATURAL FOUNDATION PROVES UNSUITABLE AS DETERMINED BY THE RESIDENT PROJECT REPRESENTATIVE AND IN ACCORDANCE WITH THE SPECIFICATIONS.

<p>CITY OF NEW PHILADELPHIA</p>	<p>STANDARD CONSTRUCTION DRAWING NO.</p>
<p>PIPE BEDDING / BACKFILL DETAIL FOR ALL RIGID WATER PIPE</p>	<p>SD-116W</p>
	<p>REV. 2-99</p>