



NOTES:

1. INVERT CHANNEL GRADES NOT TO EXCEED GRADES ON ENTERING AND EXITING PIPE RUNS.
2. ALL VOIDS TO BE FILLED WITH WATERPROOF NONSHRINKING GROUT.
3. FOR ADDITIONAL MANHOLE DETAILS, SEE SD-119.

<p>CITY OF NEW PHILADELPHIA</p>	<p>STANDARD CONSTRUCTION DRAWING NO</p>
<p>PRECAST MONOLITHIC BASE DETAIL FOR DROP MANHOLES</p>	<p>SD-123</p>
	<p>REV. 1-94</p>